



**TEST CENTRE**

# CERTIFICATE OF TESTING

**Awarded to:**

## WINDOW WAREHOUSE LIMITED

Unit 1 • Dragon Industrial Estate • Fitzherbert Road • Farlington • Portsmouth • Hants • P06 1SQ

**Standard Specification Tests against which samples were assessed:**

PAS 24-1:1999 - Enhanced Security Performance requirements for Door assemblies:-  
Including Amendments Part 1: Single and double leaf, hinged external door assemblies to dwellings .  
Nos. 1, 2, 3 and 4 and Annex A. Clauses A.4, A.5, A.6, A.7, A.8, A.9, A.10 and A.11.  
Corrigendum No. 1

**Test sample details:**

**Type:** Inwards opening, internally beaded door assembly comprising of an outer frame into which is mounted a single leaf constructed with a mid-rail. Above and below the mid-rail is a glazed insulating infill. Outer frame and leaf framing materials are manufactured from PVCu extrusions as detailed below.

**Size:** Maximum Size: Overall outer frame; 0.975 m wide x 2.100 m high.  
Overall leaf; 0.890 m wide x 2.020 m high.  
Leaf top insulating glass infill; visible area 0.750 m<sup>2</sup>  
Leaf bottom insulating glass infill; visible area 0.483 m<sup>2</sup>

**Material:** Hollow section PVCu extrusions: Halo, Eclipse.

**Hardware Utilised:** Mila; Mila Master 4RR 2 Hook Door Lock including one pice keep  
as detailed within Universal; Patriot 3D Hinges  
Test Centre Report Mila; High Security Cylinder 45/50  
Mila; Evolution High Security Cylinder Guard  
Fab & Fix; Balmoral Lever/Lever Handle set  
Mila; Fearless Hinge Protector

**Certificate No.**

# TC1780

**This Test Certificate Relates To MILA Test Centre Report No.**

# T2557

Signed:

*For & On Behalf Of The Test Centre, Mila Hardware UK Ltd.*

Test Date: 30th October 2007 Issue date 8th November 2007



**MILA TEST CENTRE**

1 Brunel Close, Drayton Fields Industrial Estate, Daventry, NN11 8RB  
Tel: 01327 - 872511, FAX: 01327 - 706676